

**Corrigendum for External HT-LT Electrical Works of New Students Hostel Building at IMD Colony,
Pashan, Pune 411008.**

Reference : SECTION -B-HT/LT SUB-STATION EQUIPMENT(HT/LT Works after MSEDCL point of supply)
BOQ Item No. 3.1 ,3.2 ,3.3 ,3.4

For L .T. PANELS : Aluminum bus bars to be considered in place of copper bus bars as per SLD and Data
sheet