

**PRE-BID M.O.M FOR RENOVATION OF CHEMISTRY LAB IN ROOM NO. 305 AND MAKING CUBICAL IN ROOM NO. 303 & 307 SECOND FLOOR PM&A DIVISION AT IITM PASHAN PUNE**

**TENDER NOTICE No. IITM/CE/RENO./PM&A/2015-16/13**

A Pre-Bid Meeting for the subject work held 08/03/2016 in Pisharoty Hall at IITM, Pune. Durring the discussion with the vendors, the following decisions were taken by the committee:

SL. No.	Points discussed	Reference	Decision Taken
01.	SCOPE OF WORK	Tender document and BOQ	<b>Scope of work was explained to vendors present in the pre-bid meeting and also the site was shown.</b>
01.	Standard Length of CAT 6 CABLE for each BOX	Tender BOQ Section C) Computer work Item no. 1	Standard Length of CAT 6 CABLE 305 meter for each Box
03.	ACID RESITANCE TILES	Tender BOQ Item no. 10	<p><b>FOR:</b> Providing and fixing 10 mm thick and (300x300) mm in size acid and/ or alkali resistant tile of approved make and colour using acid and or alkali resisting mortar bedding and joints filled with acid and /or alkali resisting cement as per IS 4457 complete as per the direction of Engineer-in-charge . In flooring on a bed of 10 mm thick mortar 1:4(1 acid proof cement: 4 coarse sand) Acid and alkali resistant tile.</p> <p><b>READ:</b> Providing and fixing 10 mm thick and (300 x 300) mm in size acid and alkali resistant tile of approved make and colour <b>fixing over existing mosaic tiles</b> surface <b>using tiles adhesive</b> with acid and or alkali resisting mortar bedding and joints filled with acid and /or alkali resisting cement <b>as per IS 4457</b> complete as per the direction of Engineer-in-charge. In flooring on a bed of 10 mm thick mortar 1:4(1 acid proof cement: 4 coarse sand) Acid and alkali resistant tile.</p> <p>[Tiles approved make JHONSON/SOMANI / ASIAN / PAVIT or equivalent &amp; alkali resisting mortar/tiles adhesive make Pedilite/Sika/Wever or equivalent]</p>
04.	COMPLETION SCHEDULE	Tender documents	Bidder should submit BAR CHART i.e. work activity completion schedule duly signed and stamped along with technical bid.
05.	BID SUBMISSION	Tender document	<p><b>Technical Bid Envelope:</b> Forwarding Letter, Copy of Pre-bid M.O.M, complete tender documents, company profile, details of work experience for similar contracts completed/in hand, BAR-CHART and related documents as mentioned in tender duly signed and stamped on each page, EMD &amp; Tender Fee.</p> <p><b>Commercial Bid Envelope: Duly filled and signed.</b></p>
<p><b>NOTE: 1) Bid should be submitted on or before due date and time i.e. 23/03/2016 at 12:30 Hrs.</b>  <b>2) Bid received after due date and time will be rejected.</b></p>			

